



**Robert E. Lee & Associates, Inc.**  
Engineering • Surveying • Environmental Services

1250 Centennial Centre Boulevard • Hobart, WI 54155 • 920-662-9641 • www.releeinc.com

**Addenda No. 2 ▲ Dated: July 9, 2018**  
**Project Name: Oneida Fishery Restoration – Phase II**  
**REL Contract No. 1041-18-01; Oneida Project No. 15-005**  
**Oneida Nation, Town of Oneida**  
**Outagamie County, Wisconsin**

**Attention Prospective Bidders.** Notice is hereby given that the contract documents for the above-referenced project are amended as hereinafter set forth:

---

**Miscellaneous**

1. Inconsistencies were found in the AutoCAD drawing that was provided to the Bidders that requested a drawing for determining earthwork volumes. There was one line that was incorrectly placed on the proposed contour layer, and one contour that was at the incorrect elevation. It is the Contractor's responsibility to verify the quantity of earthwork required to complete the project. In addition, any electronic files are provided as a convenience to the user, and any conclusion or information obtained or derived from such electronic files will be at the user's sole risk. Only printed copies (also known as hard copies) that are signed and sealed by the Engineer or surveyor may be relied upon. Any use or modification of these electronic files will be at the user's sole risk and without liability or legal exposure to Robert E. Lee & Associates, Inc. The user will be liable for the use, alteration, or incorrect interpretations of any aspect of the electronic files and shall indemnify and hold harmless Robert E. Lee & Associates, Inc., from all claims, damages, losses, and expenses, including attorneys' fees arising out of the use of the electronic files. User agrees that by his acceptance of receipt of these files, that he and any subsequent recipient, acknowledges and agrees to be bound by all of the conditions expressed herein.

**Specifications**

1. Specification Section 00 11 00, Special Provisions, Part 1.03 General Work Provisions, Item S, Specifications for "No Mow Lawn Seeding", No. 4, E, **REVISE** to read as follows:  
E. The area to be planted is as indicated on the Unit Price Bid Form.
2. Specification Section 32 90 10, Native Landscaping, Part 2.03, Erosion Control Materials, **ADD NEW** Item C to read as follows:  
C. Erosion Control Blanket stakes; metal staples shall not be allowed and all anchoring devices shall be 100 % biodegradable.

**Plan Sheets**

1. Plan Sheets 4 and 5, **REPLACE** Erosion Control Note 2 with the following:

Erosion control mat shall be placed on all slopes steeper than 5H:1V, as directed by the Engineer.

**Addenda No. 2** ▲ **Project Name:** Oneida Fishery Restoration, Phase II  
**Contract No.** 1041-18-01  
**Dated:** July 9, 2018  
**Page 2**

---

This addendum shall be attached to and form a part of these contract documents. The receipt and examination of this addendum and inclusion as a part of the contract documents shall be acknowledged by the bidder in the space provided in the Bid Form on page 00 41 13-1.

Sincerely,

ROBERT E. LEE & ASSOCIATES, INC.



Patrick H. Kuehl, P.E.  
Project Manager

PHK/LAR

Accepted this \_\_\_\_\_ day of \_\_\_\_\_, 2018

---

Signature

---

Name of Firm