



Oneida Nation
Addendum #3
9/22/23
Invitation for Bid

Construct and Equip Three Telecommunications Tower Sites

This addendum and other relevant information can be found at the following website: <https://oneida-nsn.gov/business/dts/broadband-home/>, under the “Tower Procurement Information” tab. It is the bidder’s responsibility to check this website regularly for further addenda and information.

The following questions were asked by a potential bidder:

1. The specs call for 6-gauge fence fabric. 9-gauge wire is more commonly used and want to confirm the 6-gauge is desired.
2. The specs also call for razor wire. They only have installed razor wire for prison locations and NOT ones that are easily accessible to the public, like this specific job is. Please verify or clarify what is wanted.

Please see our response below:

The Nation hereby removes the requirement for concertina wire on all fences, while retaining the requirement for the 6 Gauge fencing fabric. This change applies to all three of the tower sites. All other fencing specifications remain unchanged.

Any questions regarding this addendum should be sent via email to the SPOC at NVILLARR@oneidanation.org on or before Monday, September 18, 2023

Thank you

THE ONEIDA NATION