



Collection Date	Result (E.Coli MPN/100 mL)	Status	Reason	Flag Color
6/12/2023	4	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
6/19/2023	2	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
6/25/2023	81	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
7/5/2023	4	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
7/10/2023	2	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
7/17/2023	<1	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
7/24/2023	15	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
8/1/2023	13	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
8/7/2023	11	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
8/15/2023	36	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
8/21/2023	12	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
8/29/2023	88	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
9/7/2023	32	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
9/11/2023	40	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
9/19/2023	9	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A
9/28/2023	18	Open	Sample did NOT exceed EPA E.coli criteria for single sample maximum	N/A

Geometric Mean of Samples Collected Over a 30-day Period	28.32967
--	----------